

REQUEST FOR UTILITY REVIEW - WATER AVAILABILITY

Clark Public Utilities - Water
P. O. Box 8900 (8600 N.E. 117 Ave) Vancouver, WA 98668
TEL (360) 992-8022 FAX (360) 992-8027

APPLICANT INFORMATION

DATE. 11/23/10									
NAME K	Krista Jer	nsen/Tra	avis Johnso	n					
ADDRESS 2	2008 C S	t							
CITY \	/ancouve	er		STATE	WA	ZIP	98663		
TELEPHONE 3	360 944-6	6519		FAX					
EMAIL k	rista@pl	Isengine	ering.com	; travis@	plsenginee	ering.c	om		
Preferred means of notification: 🔲 Mail 🔛 Phone 🔲 FAX 🔯 Email									
Proposed type of				at 🖂 S	ubdivision	$\square A_1$	partment	Commercial	
Number of Lots/U	nits: 10 l	Lots							
			Pron	erty Loca	ation				
Tax Lot/Serial Acc	ct No		986028830	-	ation				
SEC 3		TWP -	4N		NGE	1E	1/4	SE	
Property Address		1514 NW 339 th St. LaC						nearest cross street)	
Property Size		37 Ac			Required Fire Flow			GPM	
· · · · · · · · · · · · · · · · · · ·	-				.,				
		PLEA	SE SURM	IT PLAT	MAP WIT	HREC	DUEST		

GENERAL CONDITIONS FOR SERVICE (CPU Staff Only)

There is an existing 8" water main within NW 339th Street and an existing 6" water main along a portion of the westerly property line (see attached water maps). These two water mains are connected to the Lower LaCenter Reservoir Pressure Zone. The Lower LaCenter Reservoir Pressure Zone is adequate to serve the southern areas of this proposed subdivision, but does not have adequate water pressure to serve the northern portions of the property. The northern area of the project shall be served by the Upper LaCenter Reservoir Pressure Zone, with a connection point at the NW Pacific Highway/W "D" Avenue intersection. Therefore, to serve the northern portion of this subdivision, connect to the existing 12" water main at the NW Pacific Highway/W "D" Avenue intersection and extend a new 12" water main westerly within NW Pacific Highway to the project site. Within the project site, the approximate dividing line between the pressure zones is at the 170' contour (approx. 50 psi static pressure). Further hydraulic analysis will be necessary to determine the exact dividing line. The hydraulic analysis shall consider historical reservoir levels (ie static pressure fluctuations). available fire flow within the NW 339th Street 8" water main (ie need to maintain a minimum of 20 psi in the system during fire flow events), and the need to provide adequate pressure (ie 50 psi or better) during normal water demand periods. An emergency flow PRV shall be installed between the two pressure zones.


DATE: 44/00/46


The Developer shall install a minimum size 8" water main (larger if needed for fire flow or domestic flow) within all the subdivision roads. Water mains shall be looped where physically possible. The Developer is responsible for all costs associated with the service installation, hydrant installations, and any other needed water improvements.


A fire flow test was performed at the existing NW 339th Street fire hydrant in 2015. The results are as follows: Static P = 76 psi, Residual P = 55 psi, Pitot P = 47 psi, and theoretical flow at 20 psi = 1944 gpm.

As the design progress, Clark Public Utilities recommends the engineer work towards fine tuning the hydraulics and the demarcation line between the two pressure zones.


☐ Clark Public Utilities has the capacity to serve, if the above conditions are met ☐ Developer/Owner shall pay County Right-of-Way fees based on off-site improvements	 ☑ Licensed Civil Eng. Drawing Required for Clark Public Utilities approval prior to construction ☑ Easement Required ☑ Clark Public Utilities has the capacity to serve, if the above conditions are met ☑ Developer/Owner shall pay County Right-of-Way fees based on off-site improvements
Review comments are subject to modification during detailed plan check and review. This utility review is valid for six months after the date of signature below. REVIEWED BY Barry Lovingood, PE	REVIEWED BY 11-28-16







Static Water Pressure Based on Lower La Center Reservoir





REQUEST FOR UTILITY REVIEW - WATER AVAILABILITY

Clark Public Utilities - Water
P. O. Box 8900 (8600 N.E. 117 Ave) Vancouver, WA 98668
TEL (360) 992-8022 FAX (360) 992-8027

APPLICANT INFORMATION

DATE: <u>10/20/16</u>							
NAME Krista Jensen / Travis Johnson ADDRESS 2008 C Street CITY Vancouver STATE WA ZIP 98663 TELEPHONE 360-944-6519 FAX 360-944-6539 EMAIL Krista@plsengineering.com / Travis@plsengineering.com							
Preferred means of notification: Mail Phone FAX Email Proposed type of development: Short Plat Subdivision Apartment Commercial Number of Lots/Units: 160							
Property Location Tax Lot/Serial Acct. No 986028830 TWP 4N RANGE 1E 1/4 SE SEC 1514 NW 339 th Street, La Center, WA 98629 (or nearest cross street) Property Size 37.42 acres Required Fire Flow GPM PLEASE SUBMIT PLAT MAP WITH REQUEST							
GENERAL CONDITIONS FOR SERVICE (CPU Staff Only)							
 □ Licensed Civil Eng. Drawing Required for Clark Public Utilities approval prior to construction □ Easement Required □ Clark Public Utilities has the capacity to serve, if the above conditions are met □ Developer/Owner shall pay County Right-of-Way fees based on off-site improvements 							
Review comments are subject to modification during detailed plan check and review. This utility review is valid for six months after the date of signature below.							
REVIEWED BY DATE							

