



A DRYWELL IS ONLY ALLOWED IF A GEOTECHNICAL ENGINEER TESTS THE SOIL AND COMPLETES A REPORT JUSTIFYING THE USE AND SIZE FOR THE SITE DRAINAGE

NOTES:

1. ALL PRECAST SECTIONS SHALL CONFORM TO REQUIREMENTS OF A.S.T.M. C478.
2. ALL PIPING TO AND FROM PRECAST DRYWELLS SHALL HAVE AT LEAST 8" OF 1-1/2" MINUS CLEAN CRUSHED ROCK COVER CONTINUOUSLY AROUND PIPE WHERE DRAIN ROCK WOULD OTHERWISE BE IN CONTACT WITH PIPE.
3. PERFORATIONS SHALL BE HORIZONTAL ROWS OF (14) 2-1/4" SQUARE OR (14) 2-3/8" ROUND HOLES, EQUALLY SPACED. ROWS SHALL BE SPACED 6-1/2" CENTER TO CENTER. PERFORATIONS SHALL BE ANGLED AS SHOWN OR HORIZONTAL.
4. STANDARD DRYWELL DEPTH SHALL BE 13 FEET UNLESS NOTED OTHERWISE.
5. ANY PROTRUDING ENDS OF PIPES SHALL BE TRIMMED FLUSH WITH THE INSIDE WALLS AND GROUTED.
6. JOINTS SHALL BE CONSTRUCTED SO AS TO BE WATERTIGHT.
7. DRYWELL MAY BE USED WHEN SPECIFICALLY APPROVED BY CITY ENGINEER.

PRECAST DRYWELL

PLAN #



CITY OF LA CENTER APPROVED

Anthony Seeloooper

4-5-17

CITY ENGINEER

DATE

REVISIONS:	DATE:	DRAWN:	DESIGNED:

SM-12