



NOTES:

1. LATERALS WILL BE CONSTRUCTED TO ENTER THE BASIN PERPENDICULAR TO THE BASIN WALL. THE LATERAL WILL ENTER ONLY AT THE FRONT OR SIDE OF THE BASIN WITH NO LATERALS ALLOWED TO ENTER THE CATCH BASIN AT THE CORNERS. IF NEEDED, A BEND MAY BE USED AS THE FIRST SECTION OF PIPE OUTSIDE THE BASIN WALL. THE MAXIMUM BEND ALLOWED IS 45 DEGREES.
1. ALL REINFORCED STEEL SHALL HAVE A 1-1/2" CLEAR COVER UNLESS OTHERWISE NOTED, AND SHALL BE GRADE 40 OR GRADE 60 (ASTM A-615).
2. ANY PROTRUDING ENDS OF PIPES SHALL BE TRIMMED FLUSH WITH THE INSIDE WALLS AND GROUTED.
3. THE METAL FRAME AND GRATE SHALL BE SET TO A SLOPE TO CONFORM TO THE PARTICULAR DRAINAGE PROBLEM.
4. ELBOW SECTION SHALL BE REMOVABLE FOR MAINTENANCE PURPOSES USING A BALL AND SPIGOT JOINT.
5. CONTRACTOR IS RESPONSIBLE FOR BLOCKING OUT ADEQUATE SPACE IN CURB AND GUTTER TO INSTALL CURB INLETS.
6. STORM INLETS SHALL BE SPACED TO CAPTURE NO MORE THAN 7,000 SQUARE FEET OF AREA.
7. DIAMETER "D" IS NORMAL DIAMETER OF OUTLET PIPE.

CURB INLET

PLAN #



CITY OF LA CENTER APPROVED

REVISIONS: DATE: DRAWN: DESIGNED:

1 9/28/10 BES BES

*Bart Stapp, PE* 9/28/10

CITY ENGINEER

DATE

SM-4