



NOMINAL JOINT SPACING:
 ① EXPANSION JOINTS AT SAWCUT ALONG LENGTH OF SIDEWALK AND CURB AND GUTTER

SECTION A-A

1. CONCRETE SHALL BE 3000 PSI MIN. (CL 3000), 3 1/2" SLUMP (MAX.).
2. COMPACT SUBGRADE AND AGGREGATE TO 95% OF MAXIMUM DRY DENSITY (3" MIN.).
3. FINISH SHALL BE MEDIUM BROOM PERPENDICULAR TO PEDESTRIAN TRAFFIC UNLESS OTHERWISE DIRECTED.
4. IN EXISTING SIDEWALK AREAS MATCH 2" SMOOTH FINISH BORDER AROUND EACH SIDEWALK PANEL IF PRESENT.
5. IF REPLACING EXISTING SIDEWALK THAT IS LESS THAN 5'-6" IN WIDTH THE MINIMUM WIDTH SHALL BE 5'.
6. ALL EXISTING EDGES SHALL BE SAWCUT.
7. CROSS SLOPE OF PLANTER STRIP SHALL BE 2% (TYP.) AND 4:1 (MAX.).
8. PLANTER STRIP IS REQUIRED ONLY FOR MAJOR AND SECONDARY ARTERIALS.

SIDEWALK CURB DRAIN DETAIL(retrofit)

PLAN #



CITY OF LA CENTER APPROVED

TONY COOPER
CITY ENGINEER

3/9/21
DATE

REVISIONS:	DATE:	DRAWN:	DESIGNED:
1	9/28/10	BES	BES
2	7/17/13	ALC	ALC
2	3/9/21	ALC	ALC

ST-26A