

- ROOT BARRIER SHALL BE BLACK, INJECTION MOLDED PANELS OR LINEAR ROLL WITH 90-DEGREE DEFLECTING RIBS.
- 2 AT A MINIMUM 12" TO MAXIMUM 18" HIGH ROOT BARRIER.
- ROOT BARRIER SHALL HAVE A MINIMUM WALL THICKNESS OF 0.06" (60 mil) & RIB THICKNESS OF 0.08" (80 mil)-THE CONTRACTOR SHALL SUBMIT MANUFACTURER SPECIFICATIONS FOR COMPLIANCE.
- 4 ROOT BARRIER SHALL BE 15' LONG: 7.5' O.C. FROM THE TREE UNLESS APPROVED BY THE CITY.
- ROOT BARRIER SHALL BE INSTALLED VERTICAL ADJACENT TO THE SIDEWALK AND CURB.

TREE ROOT BARRIER INSTALLATION							PLAN #
STOP LA CRANTAL	CITY OF LA CENTER	APPROVED	REVISIONS:	DATE:	DRAWN:	DESIGNED:	ST-31
	TONY COOPER	1/29/19					
	CITY ENGINEER	DATE					