



**NOTES:**

1. ALL CURB RAMPS SHALL MEET ADA MINIMUM REQUIREMENTS.
2. RAMPS TO BE POURED SEPARATELY AND ISOLATED BY 3/8" EXPANSION JOINT MATERIAL.
3. CROSSWALK TO BE CENTERED ON SIGNAL POLE CENTERLINES, CURB RAMPS TO BE CENTERED WITHIN CROSSWALK.
4. SIDEWALK SLOPE TO BE 2% MAXIMUM RADIALLY AROUND CORNER SECTION.
5. APPLY HEAVY BROOM FINISH ON ALL SLOPES GREATER THAN 2% IN PLACE OF DIAMOND STAMPING.
6. SEE TRUNCATED DOME DETAIL SHEET 7A
7. RAMPS SHALL HAVE A BRUSHED SURFACE TEXTURE APPLIED TO THE STILL FRESH CONCRETE.

**NOTES**

SEE STANDARD DETAIL ST-24

- a EXPANSION JOINT
- b CONSTRUCTION JOINT

**TYPE 1 CURB RAMP**

PLAN #



CITY OF LA CENTER APPROVED

*Anthony DeLooper*

4-3-17

CITY ENGINEER

DATE

REVISIONS:	DATE:	DRAWN:	DESIGNED:
1	4-3-17	ALC	ALC

ST-7